

ON SITE SEWAGE TREATMENT AND DISPOSAL SYSTEM CALCULATION:

DATA: 8 BEDROOMS WITH 7,488 S.F. OF BUILDING AREA

ESTIMATED SEWAGE FLOW CALCULATION AS PER 64E-6.008 TABLE No. I (RESIDENTIAL) 8 BEDROOMS WITH 7,488 S.F. OF BUILDING AREA760 GPD

NEW SEPTIC TANK (AS PER TABLE No. II)

AVERAGE SEWAGE FLOW 760 GALLONS/DAY...... SEPTIC TANK MIN. EFFECTIVE CAPACITY,650 GALLONS


NEW DRAINFIELD (AS PER TABLE No. III)


ESTIMATED SEWAGE FLOW (GPD) = 760 = 1,267 S.F. OF DRAINFIELD AND 633 S.F. RESERVED AREA AS REQUIRED 0.6

EXISTING SEPTIC SYSTEM: 1,500 GAL SEPTIC TANK, 800 S.F. DRAINFIELD & 400 S.F. RESERVED AREA NEW SEPTIC SYSTEM: 900 GAL SEPTIC TANK, 500 S.F. DRAINFIELD & 250 S.F. RESERVED AREA

NOTE:

THERE ARE NO PERTINENT FEATURES ON ADJACENT PROPERTIES AND ACROSS THE STREET THAT MAY AFFECT THE SYSTEM INSTALLATION.





ZONING DATA:

LOT AREA: 46,076 S.F.

ALLOWED LOT COVERAGE: 13,823 S.F. (30%)

EXISTING LOT COVERAGE: 6,221 S.F. (13.5%) NEW ADDITION LOT COVERAGE: 849 S.F. (1.8%) TOTAL NEW LOT COVERAGE: 7,070 S.F. (15.3%) REVISIONS

NNING

314

ADDITION

0

SCALE: AS SHOWN

DATE: 06/03/2014

SP-I

SHEET NO.:

Miami Dade County Department of Regulatory And Economic Resources 0000242454 - 3/31/2015 1:36:05 PM

SP-1-10152014.PDF Jerry Milbert

JoAnn Pirrello

Date Time StampDisp. TradeStamp Name10/22/2014 10:57:40 AMAPLUMApproved 10/21/2014 9:17:01 AM A PLAN HP COA Not Required Hilcia De La Cruz 10/27/2014 9:42:13 AM

DERM Trees

10/21/2014 10:45:31 AM D ZONE Disapproved

N 162 FT OF S171.78 FT OF LOT 10 LESS E1032 FT & LESS W35 FT & S 9.18 FT OF LOT IO LESS EIII4 FT & LESS W 130 FT & LESS 50.78 FT THEREOF "KINGSLEYS" SUBDIVISION ACCORDING TO THE PLAT THEREOF AS RECORDED IN PLAT BOOK I PAGE 4I OF THE PUBLIC RECORDS OF MIAMI-DADE COUNTY,

SCALE: 1/16"=1'-0"